

Single Phase Meter Bases

	200 AMP OH	200 AMP UG	320 AMP OH/UG	200 AMP COMBO W/LOAD CENTER	125/200 AMP MULTI- METER SOCKETS
Milbank	U7021-DL-TG	U1980-O	U1797-O-K3L-K2L-BL	U5168-XTL-200** U5891-X-2/200**	U125x-X-Kx Series**
Durham		1006240A*			
Eaton		UTRS223ACH			1MPxxxxRRL Series**
Square D					MPRxxxxx Series**

**Using to gain experience, prior TCEMC approval required.

Three Phase Self Contained Meter Bases

	200 AMP OH/UG	320 AMP OH/UG
Milbank	U9701-RRL-BL	U2594-X-K7-K6
Durham	UT-H7213B	UT-H7330U
Siemens	40407-0250	44707-02

Requirements

1. UL Approved with label (Underwriters Laboratories)
2. Ringless steel construction (galvanized and painted gray)
3. All Network, Multi Position, and Gang bases must have pre approval from Engineering Department.
4. Barrel lock provisions are optional.
5. Non approved meter bases will not be energized by TCEMC.
6. All UG bases require 3" knockout & slip coupling
7. Line side meter base lugs (including necessary hex nuts) are required for TCEMC to make the electrical service connection.